Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 15 Dated: 03/10/26

It is certified that an inspection team headed by ...Kunj Bihari.....

(Name of Officers with designation) from ..Junior Engineer, Panch PHED

inspected the ..Samarth move Academy Machaug, Mahuagarh/Katey9

(Name & Address of the school) on ..30/09/26 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. GP3/26/27/ 8 ..... dated..03/10/26

of D.L.W.T. Laboratory..... (PHED Lab) certified that the ..Smart move Academy.....(Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till ...Six month

Signature with Seal: 3/10/26

Name : Md Gaubar Ali

Designation : Assistant Engineer

Name & Address of the Office / Department : P.H.D Division Gp

Md. S.D.O SUB DIVISION Kalganj

To ..Smart move Academy
Machaug, Mahuagarh/Katey9
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Kunj Bihari 30/09/2026

03/10/26

Government of Bihar
Public Health Engineering Department
Water Quality Test Report

District Name: Gopalganj | Division Name: P.H.Division Gopalganj | GPJ/26/27/S1

SL. No.	Block	Panchayat	Village	Location of Source	Parameters														Date of Testing	Remarks
					pH	Turbidity (NTU)	EC	TDS (mg/l)	Total Hardness (mg/l)	Calcium (mg/l)	Magnesium (mg/l)	Chloride (mg/l)	Total Alkalinity (mg/l)	Iron (mg/l)	Nitrate (mg/l)	Sulphate (mg/l)	Fluoride (mg/l)	Total Coli		
1	Pachdewari	Kuisakhurd	Machwa / Mahuawa	Smart Move Academy	7.79	0.1	529	344	206	40	24	23	244	0.16	0.27	89.2	0.3	Absent	3/10/2026	
Desirable Limit*					6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	1.0	-		
Permissible Limit* in absence of alternate source (IS 10500:2012 - 2nd revision & Rev 2015)					NR	5.0	-	2000	600	200	100	1000	600	1.0	NR	400	1.5	**		

03/10/26
Chemist / Lab Asst
DLL, P.H. Division ,Gopalganj

AE 3/10/26
P.H.Division, Gopalganj

03/10/26
Executive Engineer
P.H.Division,Gopalganj